



SAGAR CEMENTS LIMITED, MATTAMPALLY WORKS, SURYAPET (Dist.)
TELANGANA STATE
ONLINE STACK MONITORING REPORT
Monthly Report (April-2017)

STACK PARTICULARS	SUSPENDED PARTICULATE MATTER (mg/m ³)		
	MINIMUM	MAXIMUM	AVERAGE
As per PCB Norms			30 Max.
Limestone Crusher	4.00	17.40	13.22
COOLER - 1 ESP	COOLER - 1 NOT IN OPERATION		
COOLER - 2 ESP	12.40	29.00	20.39
COAL MILL - 1	COAL MILL - 1 NOT IN OPERATION		
COAL MILL - 2	7.20	18.00	15.91
COAL MILL - 3	11.80	26.80	15.37
CEMENT MILL - 1	CEMENT MILL- 1 NOT IN OPERATION		
CEMENT MILL - 2	20.50	23.00	21.11
CEMENT MILL - 3	10.50	28.80	21.42
CEMENT MILL - 4	8.80	23.20	13.93
Parameter	SPM (mg/m ³)	SO ₂	NO _x
As per PCB norms	30 Max.	100 Max.	600 Max.
RABH MINIMUM (KILN - 2 & VRM)	21.60	10.50	447.50
MAXIMUM	27.70	14.10	559.00
AVERAGE	23.85	11.87	520.30