



SAGAR CEMENTS LIMITED, MATTAMPALLY WORKS, SURYAPET (Dist.)
TELANGANA STATE
ONLINE STACK MONITORING REPORT
Monthly Report (April-2018)

STACK PARTICULARS	SUSPENDED PARTICULATE MATTER (mg/m ³)		
	MINIMUM	MAXIMUM	AVERAGE
As per PCB Norms			30 Max.
Limestone Crusher	9.32	12.14	10.44
COOLER - 1 ESP	COOLER - 1 NOT IN OPERATION		
COOLER - 2 ESP	4.55	8.14	6.30
COAL MILL - 1	COAL MILL - 1 NOT IN OPERATION		
COAL MILL - 2	4.23	9.67	7.44
COAL MILL - 3	5.78	10.04	7.64
CEMENT MILL - 1	CEMENT MILL- 1 NOT IN OPERATION		
CEMENT MILL - 2	9.76	20.03	14.38
CEMENT MILL - 3	10.14	17.58	15.02
CEMENT MILL - 4	7.69	23.46	12.88
Parameter	SPM (mg/m ³)	SO ₂	NO _x
As per PCB norms	30 Max.	100 Max.	600 Max.
RABH MINIMUM (KILN - 2 & VRM)	9.68	1.44	104.52
MAXIMUM	24.65	4.62	485.29
AVERAGE	16.93	3.50	309.35