



SAGAR CEMENTS LIMITED, MATTAMPALLY WORKS, SURYAPET (Dist.)
TELANGANA STATE
ONLINE STACK MONITORING REPORT
Monthly Report (Aug-2018)

STACK PARTICULARS	SUSPENDED PARTICULATE MATTER (mg/m ³)		
	MINIMUM	MAXIMUM	AVERAGE
As per PCB Norms			30 Max.
Limestone Crusher	9.57	16.96	12.37
COOLER - 1 ESP	COOLER - 1 NOT IN OPERATION		
COOLER - 2 ESP	8.51	18.53	12.57
COAL MILL - 1	COAL MILL - 1 NOT IN OPERATION		
COAL MILL - 2	7.09	21.62	15.86
COAL MILL - 3	16.87	22.98	19.52
CEMENT MILL - 1	CEMENT MILL- 1 NOT IN OPERATION		
CEMENT MILL - 2	9.56	27.19	17.30
CEMENT MILL - 3	8.37	22.44	11.83
CEMENT MILL - 4	15.13	21.82	18.55
Parameter	SPM (mg/m ³)	SO ₂	NO _x
As per PCB norms	30 Max.	100 Max.	600 Max.
RABH (KILN - 2 & VRM) MINIMUM	5.62	3.58	228.50
MAXIMUM	18.53	8.58	493.57
AVERAGE	12.57	4.59	355.85