



SAGAR CEMENTS LIMITED, MATTAMPALLY WORKS, SURYAPET (Dist.)
TELANGANA STATE
ONLINE STACK MONITORING REPORT
Monthly Report (DEC-2017)

STACK PARTICULARS	SUSPENDED PARTICULATE MATTER (mg/m ³)		
	MINIMUM	MAXIMUM	AVERAGE
As per PCB Norms			30 Max.
Limestone Crusher	10.39	19.77	15.01
COOLER - 1 ESP	COOLER - 1 NOT IN OPERATION		
COOLER - 2 ESP	10.75	22.58	16.05
COAL MILL - 1	COAL MILL - 1 NOT IN OPERATION		
COAL MILL - 2	10.70	29.16	18.75
COAL MILL - 3	10.73	23.53	17.23
CEMENT MILL - 1	CEMENT MILL- 1 NOT IN OPERATION		
CEMENT MILL - 2	12.56	22.03	17.62
CEMENT MILL - 3	11.77	20.03	17.43
CEMENT MILL - 4	12.77	18.79	15.29
Parameter	SPM (mg/m ³)	SO ₂	NO _x
As per PCB norms	30 Max.	100 Max.	600 Max.
RABH (KILN - 2 & VRM) MINIMUM	10.75	1.52	284.18
MAXIMUM	19.92	3.07	458.54
AVERAGE	14.30	2.14	372.21