



SAGAR CEMENTS LIMITED, MATTAMPALLY WORKS, SURYAPET (Dist.)
TELANGANA STATE
ONLINE STACK MONITORING REPORT
Monthly Report (Feb-2020)

STACK PARTICULARS	SUSPENDED PARTICULATE MATTER (mg/m ³)		
	MINIMUM	MAXIMUM	AVERAGE
As per PCB Norms			30 Max.
Limestone Crusher	5.93	17.67	9.52
COOLER - 1 ESP	COOLER - 1 ESP NOT IN OPERATION		
COOLER - 2 ESP	5.23	12.37	8.17
COAL MILL - 1	COAL MILL - 1 NOT IN OPERATION		
COAL MILL - 2	5.86	25.19	13.12
COAL MILL - 3	5.35	19.20	14.49
CEMENT MILL - 1	CEMENT MILL- 1 NOT IN OPERATION		
CEMENT MILL - 2	6.19	14.17	10.16
CEMENT MILL - 3	4.00	13.47	5.41
CEMENT MILL - 4	11.65	23.16	16.19
Parameter	SPM (mg/m ³)	SO ₂	NO _x
As per PCB norms	30 Max.	100 Max.	800 Max.
RABH MINIMUM (KILN - 2 & VRM)	11.26	1.68	333.50
MAXIMUM	20.47	5.58	483.53
AVERAGE	13.77	3.48	411.48