



SAGAR CEMENTS LIMITED, MATTAMPALLY WORKS, SURYAPET (Dist.)
TELANGANA STATE
ONLINE STACK MONITORING REPORT
Monthly Report (July-2017)

STACK PARTICULARS	SUSPENDED PARTICULATE MATTER (mg/m ³)		
	MINIMUM	MAXIMUM	AVERAGE
As per PCB Norms			30 Max.
Limestone Crusher	15.50	28.80	20.42
COOLER - 1 ESP	COOLER - 1 NOT IN OPERATION		
COOLER - 2 ESP	7.10	27.50	18.68
COAL MILL - 1	COAL MILL - 1 NOT IN OPERATION		
COAL MILL - 2	7.10	28.60	19.84
COAL MILL - 3	10.10	21.90	18.41
CEMENT MILL - 1	CEMENT MILL- 1 NOT IN OPERATION		
CEMENT MILL - 2	9.60	26.60	19.76
CEMENT MILL - 3	12.80	28.90	20.96
CEMENT MILL - 4	11.10	24.50	16.25
Parameter	SPM (mg/m ³)	SO ₂	NO _x
As per PCB norms	30 Max.	100 Max.	600 Max.
RABH (KILN - 2 & VRM) MINIMUM	11.30	4.40	364.80
MAXIMUM	25.20	7.60	581.00
AVERAGE	18.93	6.41	465.77