



**SAGAR CEMENTS LIMITED, MATTAMPALLY WORKS, NALGONDA (Dist.,)**  
**TELANGANA STATE**  
**ONLINE STACK MONITORING REPORT**  
**Monthly Report (June-2016)**

STACK PARTICULARS	SUSPENDED PARTICULATE MATTER (mg/m <sup>3</sup> )		
	MINIMUM	MAXIMUM	AVERAGE
As per PCB Norms			50 Max.
Limestone Crusher	1.04	27.77	14.41
COOLER - 1 ESP			
COOLER - 2 ESP	9.28	35.07	22.18
COAL MILL - 1	COAL MILL - 1 NOT IN OPERATION		
COAL MILL - 2	6.31	20.86	13.59
COAL MILL - 3	7.67	21.26	14.47
CEMENT MILL - 1	CEMENT MILL- 1 NOT IN OPERATION		
CEMENT MILL - 2	8.94	25.20	17.07
CEMENT MILL - 3	7.57	26.80	17.19
CEMENT MILL - 4	12.35	15.97	14.16
Parameter	SPM (mg/m <sup>3</sup> )	SO <sub>2</sub>	NO <sub>x</sub>
As per PCB norms	50 Max.	100 Max.	600 Max.
RABH MINIMUM (KILN - 2 & VRM)	8.98	2.56	240.55
MAXIMUM	35.22	5.04	468.90
AVERAGE	22.10	3.80	354.73