



**SAGAR CEMENTS LIMITED, MATTAMPALLY WORKS, SURYAPET (Dist.)**  
**TELANGANA STATE**  
**ONLINE STACK MONITORING REPORT**  
**Monthly Report (June-2017)**

STACK PARTICULARS	SUSPENDED PARTICULATE MATTER (mg/m <sup>3</sup> )		
	MINIMUM	MAXIMUM	AVERAGE
As per PCB Norms			30 Max.
Limestone Crusher	13.00	21.70	17.14
COOLER - 1 ESP	COOLER - 1 NOT IN OPERATION		
COOLER - 2 ESP	20.90	29.10	24.43
COAL MILL - 1	COAL MILL - 1 NOT IN OPERATION		
COAL MILL - 2	7.30	29.80	16.85
COAL MILL - 3	16.10	20.80	19.62
CEMENT MILL - 1	CEMENT MILL- 1 NOT IN OPERATION		
CEMENT MILL - 2	20.30	22.40	21.21
CEMENT MILL - 3	21.00	24.20	23.04
CEMENT MILL - 4	7.90	26.70	17.99
Parameter	SPM (mg/m <sup>3</sup> )	SO <sub>2</sub>	NO <sub>x</sub>
As per PCB norms	30 Max.	100 Max.	600 Max.
RABH MINIMUM (KILN - 2 & VRM)	20.10	2.30	331.10
MAXIMUM	29.10	9.50	598.40
AVERAGE	24.57	6.26	520.76