



SAGAR CEMENTS LIMITED, MATTAMPALLY WORKS, SURYAPET (Dist.)
TELANGANA STATE
ONLINE STACK MONITORING REPORT
Monthly Report (May-2017)

STACK PARTICULARS	SUSPENDED PARTICULATE MATTER (mg/m ³)		
	MINIMUM	MAXIMUM	AVERAGE
As per PCB Norms			30 Max.
Limestone Crusher	10.10	21.20	14.10
COOLER - 1 ESP	COOLER - 1 NOT IN OPERATION		
COOLER - 2 ESP	13.70	29.80	23.52
COAL MILL - 1	COAL MILL - 1 NOT IN OPERATION		
COAL MILL - 2	17.00	29.80	21.69
COAL MILL - 3	14.80	15.40	15.19
CEMENT MILL - 1	CEMENT MILL- 1 NOT IN OPERATION		
CEMENT MILL - 2	20.20	22.50	21.05
CEMENT MILL - 3	21.40	28.80	23.11
CEMENT MILL - 4	13.70	27.20	23.07
Parameter	SPM (mg/m ³)	SO ₂	NO _x
As per PCB norms	30 Max.	100 Max.	600 Max.
RABH MINIMUM (KILN - 2 & VRM)	12.00	3.60	322.80
MAXIMUM	29.10	46.60	564.50
AVERAGE	24.13	22.00	454.90