



SAGAR CEMENTS LIMITED, MATTAMPALLY WORKS, SURYAPET (Dist.)
TELANGANA STATE
ONLINE STACK MONITORING REPORT
Monthly Report (May-2018)

STACK PARTICULARS	SUSPENDED PARTICULATE MATTER (mg/m ³)		
	MINIMUM	MAXIMUM	AVERAGE
As per PCB Norms			30 Max.
Limestone Crusher	7.84	10.61	9.54
COOLER - 1 ESP	COOLER - 1 NOT IN OPERATION		
COOLER - 2 ESP	6.49	11.15	9.18
COAL MILL - 1	COAL MILL - 1 NOT IN OPERATION		
COAL MILL - 2	5.69	16.11	9.71
COAL MILL - 3	8.40	12.64	10.93
CEMENT MILL - 1	CEMENT MILL- 1 NOT IN OPERATION		
CEMENT MILL - 2	5.96	14.54	11.09
CEMENT MILL - 3	7.23	18.92	13.34
CEMENT MILL - 4	9.21	14.71	12.03
Parameter	SPM (mg/m ³)	SO ₂	NO _x
As per PCB norms	30 Max.	100 Max.	600 Max.
RABH MINIMUM (KILN - 2 & VRM)	7.44	1.01	128.74
MAXIMUM	15.45	4.34	439.60
AVERAGE	12.26	3.17	311.88