



SAGAR CEMENTS LIMITED, MATTAMPALLY WORKS, NALGONDA (Dist.,)
TELANGANA STATE
ONLINE STACK MONITORING REPORT
Monthly Report (October-2016)

STACK PARTICULARS	SUSPENDED PARTICULATE MATTER (mg/m ³)		
	MINIMUM	MAXIMUM	AVERAGE
As per PCB Norms			50 Max.
Limestone Crusher	1.26	7.15	1.25
COOLER - 1 ESP	COOLER - 1 NOT IN OPERATION		
COOLER - 2 ESP	7.05	27.73	17.13
COAL MILL - 1	COAL MILL - 1 NOT IN OPERATION		
COAL MILL - 2	5.79	24.00	17.42
COAL MILL - 3	6.99	17.73	14.27
CEMENT MILL - 1	CEMENT MILL- 1 NOT IN OPERATION		
CEMENT MILL - 2	7.45	24.00	16.3
CEMENT MILL - 3	2.10	37.10	15.87
CEMENT MILL - 4	3.15	46.00	16.08
Parameter	SPM (mg/m ³)	SO ₂	NO _x
As per PCB norms	50 Max.	100 Max.	600 Max.
RABH MINIMUM (KILN - 2 & VRM)	1.46	1.39	127.15
MAXIMUM	26.69	5.18	486.40
AVERAGE	12.31	3.25	362.28