



**SAGAR CEMENTS LIMITED, MATTAMPALLY WORKS, SURYAPET (Dist.)**  
**TELANGANA STATE**  
**ONLINE STACK MONITORING REPORT**  
**Monthly Report (June-2020)**

STACK PARTICULARS	SUSPENDED PARTICULATE MATTER (mg/m <sup>3</sup> )		
	MINIMUM	MAXIMUM	AVERAGE
As per PCB Norms			30 Max.
Limestone Crusher	5.21	12.84	5.47
COOLER - 1 ESP	COOLER ESP - 1 NOT IN OPERATION		
COOLER - 2 ESP	5.27	10.02	7.00
COAL MILL - 1	COAL MILL - 1 NOT IN OPERATION		
COAL MILL - 2	5.11	23.75	9.52
COAL MILL - 3	5.33	19.96	8.50
CEMENT MILL - 1	CEMENT MILL- 1 NOT IN OPERATION		
CEMENT MILL - 2	CEMENT MILL- 2 NOT IN OPERATION		
CEMENT MILL - 3	6.71	17.08	11.51
CEMENT MILL - 4	6.99	15.29	9.77
Parameter	SPM (mg/m <sup>3</sup> )	SO <sub>2</sub>	NO <sub>x</sub>
As per PCB norms	30 Max.	100 Max.	600 Max.
RABH MINIMUM (KILN - 2 & VRM)	11.62	3.86	353.22
MAXIMUM	17.24	9.93	470.02
AVERAGE	14.50	5.54	399.42