



**SAGAR CEMENTS LIMITED, MATTAMPALLY WORKS, SURYAPET (Dist.)**  
**TELANGANA STATE**  
**ONLINE STACK MONITORING REPORT**  
**Monthly Report (March-2019)**

STACK PARTICULARS	SUSPENDED PARTICULATE MATTER (mg/m <sup>3</sup> )		
	MINIMUM	MAXIMUM	AVERAGE
As per PCB Norms			30 Max.
Limestone Crusher	9.91	15.10	12.69
COOLER - 1 ESP	COAL MILL - 1 NOT IN OPERATION		
COOLER - 2 ESP	9.08	17.16	12.92
COAL MILL - 1	COAL MILL - 1 NOT IN OPERATION		
COAL MILL - 2	11.17	16.58	13.52
COAL MILL - 3	7.25	14.78	11.53
CEMENT MILL - 1	CEMENT MILL- 1 NOT IN OPERATION		
CEMENT MILL - 2	8.56	24.02	13.16
CEMENT MILL - 3	6.71	23.33	14.50
CEMENT MILL - 4	9.37	13.04	11.01
Parameter	SPM (mg/m <sup>3</sup> )	SO <sub>2</sub>	NO <sub>x</sub>
As per PCB norms	30 Max.	100 Max.	600 Max.
RABH MINIMUM (KILN - 2 & VRM)	10.56	1.81	216.11
MAXIMUM	17.08	8.34	433.39
AVERAGE	14.07	5.26	321.35