



SAGAR CEMENTS LIMITED, MATTAMPALLY WORKS, SURYAPET (Dist.)
TELANGANA STATE
ONLINE STACK MONITORING REPORT
Monthly Report (Oct-2018)

STACK PARTICULARS	SUSPENDED PARTICULATE MATTER (mg/m ³)		
	MINIMUM	MAXIMUM	AVERAGE
As per PCB Norms			30 Max.
Limestone Crusher	6.13	24.61	11.66
COOLER - 1 ESP	COOLER - 1 NOT IN OPERATION		
COOLER - 2 ESP	6.16	15.00	9.17
COAL MILL - 1	COAL MILL - 1 NOT IN OPERATION		
COAL MILL - 2	8.39	26.60	14.73
COAL MILL - 3	6.85	12.94	10.59
CEMENT MILL - 1	CEMENT MILL- 1 NOT IN OPERATION		
CEMENT MILL - 2	10.39	22.82	16.33
CEMENT MILL - 3	8.24	15.31	12.30
CEMENT MILL - 4	6.34	20.12	12.63
Parameter	SPM (mg/m ³)	SO ₂	NO _x
As per PCB norms	30 Max.	100 Max.	600 Max.
RABH MINIMUM (KILN - 2 & VRM)	5.09	4.70	138.56
MAXIMUM	12.19	9.43	391.08
AVERAGE	9.68	6.23	348.42