



SAGAR CEMENTS LIMITED, MATTAMPALLY WORKS, SURYAPET (Dist.)
TELANGANA STATE
ONLINE STACK MONITORING REPORT
Monthly Report (Oct-2019)

STACK PARTICULARS	SUSPENDED PARTICULATE MATTER (mg/m ³)		
	MINIMUM	MAXIMUM	AVERAGE
As per PCB Norms			30 Max.
Limestone Crusher	3.04	16.82	7.93
COOLER - 1 ESP	COOLER - 1 ESP NOT IN OPERATION		
COOLER - 2 ESP	4.77	14.66	11.40
COAL MILL - 1	COAL MILL - 1 NOT IN OPERATION		
COAL MILL - 2	9.41	22.40	17.31
COAL MILL - 3	7.63	14.96	11.88
CEMENT MILL - 1	CEMENT MILL- 1 NOT IN OPERATION		
CEMENT MILL - 2	5.09	8.00	5.60
CEMENT MILL - 3	9.52	20.94	11.88
CEMENT MILL - 4	4.84	19.70	12.92
Parameter	SPM (mg/m ³)	SO ₂	NO _x
As per PCB norms	30 Max.	100 Max.	800 Max.
RABH MINIMUM (KILN - 2 & VRM)	7.89	1.64	165.92
MAXIMUM	10.11	2.38	369.66
AVERAGE	8.47	2.03	334.68