



SAGAR CEMENTS LIMITED, MATTAMPALLY WORKS, SURYAPET (Dist.)
TELANGANA STATE
ONLINE STACK MONITORING REPORT
Monthly Report (Sep-2019)

STACK PARTICULARS	SUSPENDED PARTICULATE MATTER (mg/m ³)		
	MINIMUM	MAXIMUM	AVERAGE
As per PCB Norms			30 Max.
Limestone Crusher	5.61	19.22	12.92
COOLER - 1 ESP	COOLER - 1 ESP NOT IN OPERATION		
COOLER - 2 ESP	6.13	12.10	9.04
COAL MILL - 1	COAL MILL - 1 NOT IN OPERATION		
COAL MILL - 2	8.04	19.70	13.13
COAL MILL - 3	5.49	12.26	8.37
CEMENT MILL - 1	CEMENT MILL- 1 NOT IN OPERATION		
CEMENT MILL - 2	CEMENT MILL- 2 NOT IN OPERATION		
CEMENT MILL - 3	7.33	16.76	11.58
CEMENT MILL - 4	6.00	15.55	10.14
Parameter	SPM (mg/m ³)	SO ₂	NO _x
As per PCB norms	30 Max.	100 Max.	800 Max.
RABH MINIMUM (KILN - 2 & VRM)	7.42	1.01	194.73
MAXIMUM	12.84	9.34	376.57
AVERAGE	9.46	3.87	307.11